

Fargodome Fire Marshal Requirements

All booths must be in compliance with the following requirements or the whole show may be shut down!



If your exhibit contains any petroleum based products (i.e. gasoline) the following guidelines must be met:

1. The gas tanks must be less than 1/3 full of fuel.
2. The gas tanks must be taped shut.
3. The battery terminals must be disconnected.

Displaying Grills

All grill units that are displayed while “hot” in any vendor booth must be placed in the back half of the booth. Due to the large volume of people attending the show, grills are not to be permitted in the front half of any booth space.

LP Gas to Fuel Grills, Fireplaces

The Fargo Fire Marshal will not allow any LP gas tanks in the building to be larger than five pounds. Tanks may be attached to each display unit, but the tanks must be kept a minimum of 20 feet apart. Units may be turned on and off for demonstration, as long as no two or more units in use are within 20 feet of each other. Additional tanks should be stored in your vehicle/trailer.

Parking During Move-In

Do not park on the sidewalks! It blocks the doors, and because of this, it is against fire code. You may park in front of the doors only to drop off. DO NOT leave your vehicle unattended. If you are parked illegally, the FARGODOME will have your vehicle towed away.

Thank you for your cooperation!
For questions call the HBA at (701) 232-5846.